

GOVERNMENT OF ARUNACHAL PRADESH
DIRECTORATE OF FIRE & EMERGENCY SERVICES
ITANAGAR

No.DIR/F&ES/MT-200/2026


Dated Itanagar the 11th Sept' 2026

// CORRIGENDUM //

Reference:- This office Tender Notice No.DIR/F&ES/MT-200/2026 dated 28/08/2026 regarding supply of 6[six] Medium Fire tenders for Arunachal Pradesh Fire & Emergency Services during 2026-27.

The following corrections have been made in the Technical Specifications of Fire tenders as detailed below:-

A) TECHNICAL SPECIFICATION FOR SUPPLY OF 6[SIX]FIRE TENDERS	
Point No.5.1	The pump shall be like Rosenbauer/Godiva/FIREFLY/Hale make compliance with CE and UL certification confirming to EN 1028 standard and shall be a low pressure rear mounted pump with output capacity of 2270 LPM at 7 Kg/cm2.
Point No.5.8	The pump priming shall be fully automatic in operation and shall not require any operation whatever on the pump operator other than throttling the engine to the required RPM. The pump shall give its rated output with an engine and pump input at shaft speed safe enough to operate the engine.


Superintendent of Police
Fire & Emergency Services
Arunachal Pradesh
Itanagar

Memo No.DIR/F&ES/MT-200/2026

Dated Itanagar the 11th Sept' 2026

Copy to:-

1. The I/c Computer Cell, PHQ, Itanagar to upload this corrigendum on the Arunachal Pradesh Police website www.arunpol.nic.in.
2. Office copy.


Superintendent of Police
Fire & Emergency Services
Arunachal Pradesh
Itanagar